



THIS IS TO CERTIFY THAT THE:

M & N / FSM FILTERSCREEN

WAS TESTED AT THE:

**NATIONAL SCREEN EVALUATION FACILITY
CHESTER LE STREET STW
NORTHUMBRIAN WATER**

OCTOBER 2013

AVERAGE SCREENINGS CAPTURE RATIO = 85%

FOR FURTHER DETAILS REFER TO:

THOMPSON RPM REPORT REF- TRPM-REP275

A handwritten signature in blue ink that reads "Barry Thompson".

Barry Thompson
Thompson RPM Ltd